




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	OFFECCT		
<b>Object:</b>	Soundsticks®		
<b>Size [mm]:</b>	w = 1240	h = 95	d = 95

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.2
250	0.6
500	1.4
1000	2.2
2000	2.7
4000	3
<b>N<sub>10</sub> = 7.1</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan 18-732-M1	2019-01-31

