




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	OFFECCT		
Object:	Soundsticks® Cluster		
Size [mm]:	w = 1240	h = 95	d = 95

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.1
250	0.6
500	1.4
1000	2.1
2000	2.5
4000	2.6
N₁₀ = 7.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan 18-732-M2	2019-01-23

