SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Soneo Table		
Size [mm]:	w = 800	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0.14
125	0.2
250	0.36
500	0.49
1000	0.63
2000	0.72
4000	0.78
N_{10} =	20.4

Equivalent sound absorption area / unit



Frequency, Hz

ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 15-065-R1 (preliminary)	2015-04-10

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com