




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Soneo Table		
Size [mm]:	w = 1000	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.21
125	0.27
250	0.49
500	0.69
1000	0.8
2000	0.88
4000	0.95
N₁₀ = 14.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 15-065-M2 (preliminary)	2015-04-10

