




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Soneo Table		
<b>Size [mm]:</b>	w = 1400	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.28
125	0.37
250	0.68
500	0.94
1000	1.12
2000	1.24
4000	1.34
<b>N<sub>10</sub> = 10.6</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 15-065-R1 (preliminary)	2015-04-10

