




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Soneo Table		
Size [mm]:	w = 1800	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.39
125	0.45
250	0.87
500	1.14
1000	1.45
2000	1.63
4000	1.71
N₁₀ = 8.8	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 15-065-R1 (preliminary)	2015-04-10

