




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Soneo Table		
Size [mm]:	w = 2000	h = 650	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.41
125	0.5
250	0.96
500	1.26
1000	1.61
2000	1.81
4000	1.91
N₁₀ = 7.9	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 15-065-R1 (preliminary)	2015-04-10

