




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	dB Pillar 700		
<b>Size [mm]:</b>	w = 700	h = 470	d = 369

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.3
125	0.66
250	0.77
500	0.88
1000	1.02
2000	1.04
4000	1.14
<b>N<sub>10</sub> = 11.4</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
KTH-MWL ABSTRACTA 20200107 Object A10	2020-01-10

