




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

|                   |              |          |        |
|-------------------|--------------|----------|--------|
| <b>Client:</b>    | Abstracta    |          |        |
| <b>Object:</b>    | Trumpet 1040 |          |        |
| <b>Size [mm]:</b> | w = 515      | h = 1040 | d = 80 |

| Octave band (Hz)     | Equivalent sound absorption area / unit (m <sup>2</sup> Sabine) |
|----------------------|---|
| 63                   | 0.08  |
| 125                  | 0.1   |
| 250                  | 0.4   |
| 500                  | 0.5   |
| 1000                 | 0.5   |
| 2000                 | 0.5   |
| 4000                 | 0.6   |
| N <sub>10</sub> = 20 |   |



|                                  |                       |
|----------------------------------|-----------------------|
| <b>ORIGINAL TEST REPORT</b>      | <b>DATE OF REPORT</b> |
| Akustikverkstan report 17-094-R1 | 2017-05-10            |

