




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

| | | | |
|-------------------|--------------|----------|--------|
| Client: | Abstracta | | |
| Object: | Trumpet 2040 | | |
| Size [mm]: | w = 515 | h = 2040 | d = 80 |

| Octave band (Hz) | Equivalent sound absorption area / unit (m ² Sabine) |
|------------------------------|---|
| 63 | 0.1 |
| 125 | 0.2 |
| 250 | 0.8 |
| 500 | 0.9 |
| 1000 | 1 |
| 2000 | 1.1 |
| 4000 | 1.2 |
| N₁₀ = 11.1 | |



| | |
|-----------------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| Akustikverkstan report 17-094-M13 | 2017-05-10 |

