



SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Client:

Object: Reindeer Moss CONVEX

Size [mm]: w = 600 h = 600 d = 120

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.1
250	0.3
500	0.5
1000	0.6
2000	0.6
4000	0.6
N ₁₀ = 20	



ORIGINAL TEST REPORT

19-725-M5

DATE OF REPORT

2019-12-11

