




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Glimakra Of Sweden		
Object:	Sabine		
Size [mm]:	w = 770	h = 1524	d = 396

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.5
125	1.1
250	1.8
500	1.3
1000	2
2000	2.2
4000	2.2
N₁₀ = 7.7	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 14-180-M1	2014-12-11

