




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Domo table screen A1		
Size [mm]:	w = 1800	h = 650	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.3
250	0.3
500	0.6
1000	1
2000	1
4000	1.1
N₁₀ = 16.7	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 14-125-M9	2014-09-26

