



SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Client:

Object: Platz

Size [mm]: w = 2400 h = 1200 d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.9
250	2
500	3.1
1000	3.4
2000	3.1
4000	3
N ₁₀ = 3.3	



ORIGINAL TEST REPORT

Akustikverkstan report 19-728-M3

DATE OF REPORT

2019-07-10

