



SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Client:

Object: Platz

Size [mm]: w = 2400 h = 1200 d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	1
250	2.3
500	3.5
1000	4
2000	3.4
4000	3.3
N ₁₀ = 3	



ORIGINAL TEST REPORT

Akustikverkstan report 19-728-M4

DATE OF REPORT

2019-07-10

