




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Vibe (floor screen)		
Size [mm]:	w = 1165	h = 1800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.4
125	0.6
250	1.6
500	2.3
1000	3
2000	3.1
4000	3.2
N₁₀ = 4.3	



ORIGINAL TEST REPORT	DATE OF REPORT
19-713-M8	2019-05-06

