




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Kinnarps		
<b>Object:</b>	Vibe (desk screen)		
<b>Size [mm]:</b>	w = 840	h = 650	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.11
125	0.22
250	0.41
500	0.58
1000	0.72
2000	0.78
4000	0.87
<b>N<sub>10</sub> = 17.2</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 21-723-M1	2021-05-18

