




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

| | | | |
|-------------------|--------------------|---------|--------|
| Client: | Kinnarps | | |
| Object: | Vibe (desk screen) | | |
| Size [mm]: | w = 840 | h = 650 | d = 40 |

| Octave band (Hz) | Equivalent sound absorption area / unit (m ² Sabine) |
|------------------------------|---|
| 63 | 0.11 |
| 125 | 0.22 |
| 250 | 0.41 |
| 500 | 0.58 |
| 1000 | 0.72 |
| 2000 | 0.78 |
| 4000 | 0.87 |
| N₁₀ = 17.2 | |



| | |
|----------------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| Akustikverkstan report 21-723-M1 | 2021-05-18 |

