




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Vibe (desk screen)		
Size [mm]:	w = 1200	h = 650	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.18
125	0.27
250	0.62
500	0.81
1000	0.99
2000	1.2
4000	1.3
N₁₀ = 12.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-723-M3	2021-05-18

