




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

|                   |                    |         |        |
|-------------------|--------------------|---------|--------|
| <b>Client:</b>    | Kinnarps           |         |        |
| <b>Object:</b>    | Vibe (desk screen) |         |        |
| <b>Size [mm]:</b> | w = 1400           | h = 650 | d = 40 |

| Octave band (Hz)     | Equivalent sound absorption area / unit (m <sup>2</sup> Sabine) |
|----------------------|---|
| 63                   | 0.22  |
| 125                  | 0.33  |
| 250                  | 0.72  |
| 500                  | 1   |
| 1000                 | 1.3   |
| 2000                 | 1.4   |
| 4000                 | 1.5   |
| N <sub>10</sub> = 10 |   |



|                                  |                       |
|----------------------------------|-----------------------|
| <b>ORIGINAL TEST REPORT</b>      | <b>DATE OF REPORT</b> |
| Akustikverkstan report 21-723-M7 | 2021-05-26            |

