




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

| | | | |
|-------------------|--------------------|---------|--------|
| Client: | Kinnarps | | |
| Object: | Vibe (desk screen) | | |
| Size [mm]: | w = 2000 | h = 650 | d = 40 |

| Octave band (Hz) | Equivalent sound absorption area / unit (m ² Sabine) |
|-----------------------------|---|
| 63 | 0.3 |
| 125 | 0.37 |
| 250 | 1 |
| 500 | 1.5 |
| 1000 | 1.9 |
| 2000 | 2 |
| 4000 | 2.3 |
| N₁₀ = 6.7 | |



| | |
|----------------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| Akustikverkstan report 21-723-M8 | 2021-05-26 |

