




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Vibe (desk screen)		
Size [mm]:	w = 1200	h = 800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.21
125	0.32
250	0.74
500	1.1
1000	1.3
2000	1.4
4000	1.5
N₁₀ = 9.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-723-M4	2021-05-18

