




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Vibe (desk screen)		
Size [mm]:	w = 1400	h = 800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.27
125	0.37
250	0.87
500	1.2
1000	1.5
2000	1.7
4000	1.8
N₁₀ = 8.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-723-M10	2021-05-26

