




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Vibe (desk screen)		
Size [mm]:	w = 2000	h = 800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.35
125	0.47
250	1.2
500	1.8
1000	2.3
2000	2.4
4000	2.6
N₁₀ = 5.6	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-723-M11	2021-05-26

