




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Kinnarps		
<b>Object:</b>	Vibe (desk screen)		
<b>Size [mm]:</b>	w = 2000	h = 800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.35
125	0.47
250	1.2
500	1.8
1000	2.3
2000	2.4
4000	2.6
<b>N<sub>10</sub> = 5.6</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 21-723-M11	2021-05-26

