




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Prim Hanging Screen 160x198		
Size [mm]:	w = 1600	h = 1980	d = 55

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.5
125	1.3
250	2.9
500	4.6
1000	5.6
2000	5.9
4000	5.7
N₁₀ = 2.2	



ORIGINAL TEST REPORT	DATE OF TEST
SP report 4P03869	2014-06-19

