




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	OFFECCT
Object:	Soundwave® Jasmine 6 pcs
Size [mm]:	w = 1025 h = 1176 d = 73

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.06
125	0.11
250	0.64
500	0.66
1000	0.64
2000	0.58
4000	0.57
N₁₀ = 17.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 20-752-M3	2020-11-27

