




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

|                   |                                    |
|-------------------|------------------------------------|
| <b>Client:</b>    | OFFECCT                            |
| <b>Object:</b>    | Soundwave® Jasmine BF 6 PCS.       |
| <b>Size [mm]:</b> | w = 1025      h = 1176      d = 73 |

| Octave band (Hz)             | Equivalent sound absorption area / unit (m <sup>2</sup> Sabine) |
|------------------------------|---|
| 63                           | 0.06  |
| 125                          | 0.15  |
| 250                          | 0.77  |
| 500                          | 0.81  |
| 1000                         | 0.72  |
| 2000                         | 0.58  |
| 4000                         | 0.55  |
| <b>N<sub>10</sub> = 18.2</b> |   |



|                                  |                       |
|----------------------------------|-----------------------|
| <b>ORIGINAL TEST REPORT</b>      | <b>DATE OF REPORT</b> |
| Akustikverkstan report 20-752-M4 | 2020-11-27            |

