




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	OFFECCT
<b>Object:</b>	Soundwave® Jasmine BF 6 PCS.
<b>Size [mm]:</b>	w = 1025      h = 1176      d = 73

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.06
125	0.15
250	0.77
500	0.81
1000	0.72
2000	0.58
4000	0.55
<b>N<sub>10</sub> = 18.2</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 20-752-M4	2020-11-27

