




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	OFFECCT
Object:	Soundwave® Jasmine BF 6 PCS.
Size [mm]:	w = 1025 h = 1176 d = 73

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.06
125	0.15
250	0.77
500	0.81
1000	0.72
2000	0.58
4000	0.55
N₁₀ = 18.2	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 20-752-M4	2020-11-27

