




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Decibel AB		
<b>Object:</b>	Clamp Wall Round		
<b>Size [mm]:</b>	w = 600	h = 0	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.02
125	0.06
250	0.2
500	0.5
1000	0.5
2000	0.42
4000	0.38
<b>N<sub>10</sub> = 26.3</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 21-738-M17	2021-10-29

