




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Decibel AB		
<b>Object:</b>	Bow (6 pcs)		
<b>Size [mm]:</b>	w = 600	h = 600	d = 100

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.15
125	0.63
250	1.7
500	2.8
1000	2.7
2000	2.6
4000	2.8
<b>N<sub>10</sub> = 3.8</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 20-759-M2	2021-01-07

