




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Cubic 200		
Size [mm]:	w = 400	h = 400	d = 2000

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.4
125	1.2
250	2
500	2.6
1000	3.2
2000	3.2
4000	3.1
N₁₀ = 3.8	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 20-702-M1	2020-01-14

