




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Decibel AB		
<b>Object:</b>	Facett (6 pcs)		
<b>Size [mm]:</b>	w = 600	h = 600	d = 100

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.09
125	0.69
250	1.9
500	2.8
1000	2.7
2000	2.5
4000	2.4
<b>N<sub>10</sub> = 4.2</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 21-737-M2	2021-09-03

