




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Facett (6 pcs)		
Size [mm]:	w = 600	h = 600	d = 100

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.09
125	0.69
250	1.9
500	2.8
1000	2.7
2000	2.5
4000	2.4
N₁₀ = 4.2	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-737-M2	2021-09-03

