




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons, Akustikmiljö / Am Acoustics		
Object:	Cobogo (3 groups of 12 units)		
Size [mm]:	w = 372	h = 372	d = 5

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.03
250	0.07
500	0.19
1000	0.43
2000	0.67
4000	0.89
N₁₀ = 52.6	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 22-702-M3	2022-02-28

