




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Blå Station		
Object:	Ginkgo 30pcs		
Size [mm]:	w = 2000	h = 1850	d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.2
125	0.6
250	2.3
500	3.4
1000	3
2000	2.8
4000	2.6
N₁₀ = 3.8	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 14-117-R1	2015-06-08

