




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Integrated		
Size [mm]:	w = 600	h = 800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.13
125	0.19
250	0.34
500	0.42
1000	0.49
2000	0.6
4000	0.76
N₁₀ = 23.8	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-701-M1a	2018-08-23

