




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Integrated		
Size [mm]:	w = 800	h = 1400	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.36
125	0.48
250	0.76
500	0.95
1000	1.2
2000	1.4
4000	1.7
N₁₀ = 10.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-701-M4a	2018-08-23

