




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 600	h = 800	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.07
125	0.16
250	0.38
500	0.6
1000	0.81
2000	0.87
4000	0.99
N₁₀ = 16.7	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M1	2021-06-23

