




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 600	h = 1000	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.11
125	0.21
250	0.48
500	0.74
1000	1
2000	1.1
4000	1.2
N₁₀ = 13.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M2	2021-07-12

