




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Boom Interior		
<b>Object:</b>	Xrozz Absorption Plus		
<b>Size [mm]:</b>	w = 600	h = 1200	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.14
125	0.25
250	0.57
500	0.87
1000	1.2
2000	1.3
4000	1.4
<b>N<sub>10</sub> = 11.5</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 21-720-M3	2021-06-23

