




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 600	h = 1200	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.14
125	0.25
250	0.57
500	0.87
1000	1.2
2000	1.3
4000	1.4
N₁₀ = 11.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M3	2021-06-23

