




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 600	h = 1400	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.18
125	0.29
250	0.64
500	1
1000	1.4
2000	1.5
4000	1.6
N ₁₀ = 10	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M4	2021-07-12

