




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 600	h = 1600	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.22
125	0.33
250	0.71
500	1.2
1000	1.6
2000	1.7
4000	1.9
N₁₀ = 8.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M6	2021-07-12

