




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 600	h = 1800	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.27
125	0.4
250	0.81
500	1.3
1000	1.8
2000	1.9
4000	2.1
N₁₀ = 7.7	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M6	2021-07-12

