




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Boom Interior		
<b>Object:</b>	Xrozz Absorption Plus		
<b>Size [mm]:</b>	w = 600	h = 2000	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.3
125	0.45
250	0.91
500	1.5
1000	1.9
2000	2.1
4000	2.3
<b>N<sub>10</sub> = 6.7</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 21-720-M7	2021-07-12

