




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 600	h = 2000	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.45
250	0.91
500	1.5
1000	1.9
2000	2.1
4000	2.3
N₁₀ = 6.7	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M7	2021-07-12

