




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 800	h = 800	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.12
125	0.22
250	0.51
500	0.78
1000	1.1
2000	1.1
4000	1.2
N₁₀ = 12.8	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M8	2021-07-12

