


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 800	h = 1400	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.28
125	0.42
250	0.84
500	1.4
1000	1.8
2000	1.9
4000	2.2
N₁₀ = 7.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M11	2021-06-23

